


RPC Air conditioned enclosure in building 904



x2 room 29.5 x 9.5m = 280m²
 7.5 x 15.5m = 116m²

Thermal coefficient (Walls)	U=0.5 [W/m ² .K]	Internal height	≥ 3.5m
Thermal coefficient (Windows)	U = 1 – 1.4 [W/m ² .K]	External height	≤ 4.3m
Roof load	150kg	False ceiling height	≥ 0.3m
X2	Airlocks(SAS)	Pressure inside	10Pa