

The radiation field in the Gamma Irradiation Facility GIF++ at CERN

Dorothea Pfeiffer^{a,b,*}, Georgi Gorine^{c,a}, Hans Reithler^d,
Bartolomej Biskup^{a,e}, Alasdair Day^a, Adrian Fabich^a, Joffrey Germa^a,
Roberto Guida^a, Martin Jaekel^a, Federico Ravotti^a

^a*CERN, CH-1211 Geneva 23, Switzerland*

^b*European Spallation Source (ESS ERIC), P.O. Box 176, SE-22100 Lund, Sweden*

^c*Ecole Polytechnique Fédérale de Lausanne(EPFL), CH-1015 Lausanne, Switzerland*

^d*RWTH Aachen University, Aachen, Germany*

^e*Institute of Experimental and Applied Physics, Czech Technical University in Prague,
Czech Republic*

Abstract

The high-luminosity LHC (HL-LHC) upgrade is setting now a new challenge for particle detector technologies. The increase in luminosity will produce a particle background in the gas-based muon detectors that is ten times higher than under conditions at the LHC. The detailed knowledge of the detector performance in the presence of such a high background is crucial for an optimized design and efficient operation after the HL-LHC upgrade. A precise understanding of possible aging effects of detector materials and gases is of extreme importance. To cope with these challenging requirements, a new Gamma Irradiation Facility (GIF++) was designed and built at the CERN SPS North Area as successor of the Gamma Irradiation Facility (GIF) during the Long Shutdown 1 (LS1) period. It features an intense source of 662 keV photons with adjustable intensity, to simulate continuous background over large areas, and, combined with a high energy muon beam, to measure detector performance in the presence of the background. The new GIF++ facility has been operational since spring 2015. In addition to describing the facility and its infrastructure, the goal of this work is to provide an extensive characterization of the GIF++ photon field with different configurations of the absorption filters in both the upstream and downstream irradiation areas.

*Corresponding author: dorothea.pfeiffer@cern.ch

Moreover, the measured results are benchmarked with Geant4 simulations to enhance the knowledge of the radiation field. The absorbed dose in air in the facility may reach up to 2.2 Gy/h directly in front of the irradiator. Of special interest is the low-energy photon component that develops due to the multiple scattering of photons within the irradiator and from the concrete walls of the bunker.

Keywords: Gamma irradiation, irradiation facility, detector test, ^{137}Cs source, Geant4, simulation

1. Introduction

The Gamma Irradiation Facility (GIF) [1] at CERN [2], the European Organization for Nuclear Research, was extensively used from 1997 until its closure in 2014 for the characterization of particle detectors. Located in the former CERN SPS West Area, the facility played in particular an important role in testing large area muon detector systems and components for the Large Hadron Collider (LHC) [3]. In this facility, detectors could simultaneously be exposed to the photons from a ^{137}Cs source and to a high-energy muon beam. Although from 2005 onwards only the caesium source was available, the GIF continued to be fully exploited all year round by a wide community of users. The high-luminosity LHC (HL-LHC) upgrade [4] is setting now a new challenge for particle detector technologies. The increase in luminosity will produce a particle background in the gas-based muon detectors that is an order of magnitude higher than under present conditions at the LHC, hence detector tests at accordingly higher rates are required. The detailed knowledge of the detector performance in the presence of such a high background is crucial for an optimized design and efficient operation after the HL-LHC upgrade. A precise understanding of possible aging effects of detector materials and gases is also of extreme importance. To cope with these challenging requirements, a new Gamma Irradiation Facility (GIF++) was designed and built at the CERN SPS North Area¹ during the Long Shutdown 1 (LS1) period [5]. Whereas CERN was responsible for the construction of the facility and the procurement of the irradiator, a comprehensive user infrastructure was provided within the framework of the FP7 AIDA project [6].

¹Zone EHN1, building 887

The new GIF++ facility offers two separated irradiation areas and has been operational since spring 2015.

The goal of this note is to provide an extensive characterization of the GIF++ photon field with different configurations of the absorption filters in both the upstream and downstream irradiation areas. Measured dose rates are benchmarked with Geant4 [7] simulations to enhance the knowledge of the radiation field. Of special interest is the low-energy photon component that develops due to the multiple scattering of photons within the irradiator and from the concrete walls of the bunker. A detailed description of the shielding of the GIF++ bunker and its optimization with the help of Monte Carlo simulations can be found in reference [8].

2. The GIF++ facility

2.1. Layout of the facility

Focused on the characterization and understanding of the long-term behavior of large gas-based particle detectors, GIF++ combines a ^{137}Cs source with two sets of adjustable filters to vary the intensity², and a high-energy muon beam (100 GeV/c) from the secondary SPS beam line H4 in EHN1. The ^{137}Cs isotope was chosen instead of ^{60}Co due to its long half-life of 30.08 years, leading to a smaller decrease of the photon rate over the expected lifetime of this facility. The layout of the GIF++ facility and the used coordinate system are shown in figure 1.

2.2. High-energy reference beams

Located near the end of the beam line H4, GIF++ is the main user of this beam line for six to eight weeks per year. In addition, the facility receives parasitic muon beam halo for 30-50% of the SPS operation time. The muon beam is generated as a secondary beam from the primary SPS proton beam on a production target. The spectrometer of the H4 beam line allows the beam line user to choose the nominal momentum of the secondary beam with a maximum momentum of 400 GeV/c. The muon beam in the energy range of 57-100% of the nominal beam energy is mainly generated by the decay of pions and kaons that are produced in the primary target. Depending on the

²Source activity: 14.9 TBq in November 2011, 13.9 TBq in March 2015, 13.5 TBq in March 2016




Figure 1: Floor plan of the GIF++ facility. When the facility downstream of the GIF++ takes electron beam, a beam pipe is installed along the beam line (z-axis). The irradiator can be displaced laterally (its center moves from $x = 0.65$ m to 2.15 m), to increase the distance to the beam pipe.

beam line settings, either the full bandwidth or an energy spread reduced to the percent level is transported to the GIF++ area. The spill structure of the muon beam follows the primary proton beam structure, which has a spill of 4.8 seconds with a close to flat distribution. Depending on the SPS cycling for other users (e.g. LHC), one spill arrives about every 30 seconds on average. With the full acceptance of the beam line, the intensity can be up to 10^4 muons per spill, which is limited by radiation protection aspects. The secondary beam can also be adjusted for hadrons and/or electrons. For about five weeks per year the main user of the H4 beam line is a user downstream, who uses an electron beam. During this time an evacuated pipe is installed all along the beam line in the GIF++ bunker. The lateral distribution of the muon beam at the GIF facility depends on several factors like the final focusing, which can be varied within a large range. In case of parasitic use, the settings chosen by the primary beam line user upstream determine the intensity and energy. As a general rule, the core of the muon beam covers a surface of 10 cm x 10 cm, containing half of the muon beam. The remaining part of the muon beam, the beam halo, is spread over a footprint of about

1 m².

2.3. Irradiator and filter system

Gamma irradiation is however available throughout the whole year, except during short maintenance periods. The 100 m² GIF++ bunker is about 5 m high and has two independent irradiation zones (named as upstream and downstream in figure 1), making it possible to test simultaneously several real size detectors, with a size of up to several square meters, as well as a broad range of smaller prototype detectors and electronic components. The GIF++ irradiator and its filter systems are depicted in figure 2. The irradiator has been developed in cooperation with the Czech company VF a.s. [9]. The caesium source can be moved from the garage position at the bottom of the support tube inside the shielded receptacle to the irradiation position at the top of the tube.

With two $\pm 37^\circ$ panoramic collimators, the irradiation zone covers a large part of the bunker area, both in the downstream and upstream regions. As shown in figure 2a, both collimators are equipped with a lens shaped angular correction filter to provide a uniform photon distribution over a plane, as needed for flat large area detectors. Embedded inside a common enclosure, two complete and independent attenuation systems are available (figure 2b), each consisting of an array of 3x3 lead attenuation filters, to fine tune the photon flux for each irradiation field individually. A collaboration with the RWTH Aachen [10] took care of design and production of the angular correction and attenuation filters. Mounted on aluminum support plates, the filters are positioned inside steel frames and connected to counterweights moving on the side of the irradiator. There are three planes of filters (A,B,C), with three filters per plane. The filters have the nominal attenuation factors 1 (A1,B1,C1), 1.5 (B2), 2.2 (C2), 4.6 (C3), 10 (A2) and 100 (A3, B3). The total attenuation factor, from the three filter layers, can be set both via a dedicated control panel, as well as via the GIF++ control system. In total, 24 different nominal attenuation factors between 1 and 46415 can be selected according to the 27 possible combinations. The factors were chosen to be nearly equidistant, on a logarithmic scale, over the first three orders of magnitude, as illustrated in figure 2c. The irradiator and the two filter systems are mounted on rails, so that the whole assembly can be moved in the direction transverse to the muon beam.




Figure 2: Schematic drawing of the GIF++ irradiator with angular correction filters and independent filter systems at both sides. Each set of 3x3 movable attenuation filters, with 27 combinations of filters, leads to 24 different attenuation factors between 1 and 46415. The two collimators have vertically and horizontally an opening of $\pm 37^\circ$ with respect to the beam axis.

2.4. Angular correction filter and attenuation filters: Adjustment of current

Without the angular correction filter, the GIF++ source would be approximately a point source. The angular correction filter, made of steel, is shaped in such a way, that the $\frac{1}{r^2}$ dependence of the photon current is replaced by a uniform current in each xy plane. The $\pm 37^\circ$ opening of the irradiator collimators allows horizontally and vertically angles θ (angle between the incoming photon and the surface normal of the filter) from 0° in the center of the filter to 46.8° in the corners of the collimator. To reach a uniform current, the photons have to be attenuated with a factor of $\cos^{-3}(\theta - 46.8^\circ)$. That means that the photons in the center of the filter are attenuated by a factor of $\cos^{-3}(46.8^\circ)$, whereas the photons in the corners of the collimators are not attenuated. Each angle of incidence corresponds to a different path length traversed in the filter. The actual attenuation of the photon depends on this path length and the linear attenuation coefficient μ of the material³. The thickness of the angular correction filter varies for each angle of incidence in such a way, that the desired attenuation is reached for all 662 keV photons. Here attenuation can either mean that the photon has lost energy, or that it has been fully absorbed. For photons with lower energies, created due to scattering in the source capsule and the collimator of the irradiator, the angular correction filter leads to a less uniform current.

For the attenuation filters, on the other hand, the attenuation factor does not depend on the angle of incidence of the photons. Photons with all angles of incidence traverse the same thickness of material and undergo the same attenuation. The nominal attenuation factor is again defined as attenuation of 662 keV photons; photons with lower energy are attenuated to a larger degree. Due to the presence of lower energy photons, the effective total attenuation over the whole spectral range is lower than the nominal attenuation. The exact value will depend on the spectral sensitivity of the detector used, as well as on the presence of other objects in the bunker. Figure 3 shows the simulated current of 662 keV photons in the GIF++ facility in the yz plane for an attenuation factor 1, i.e. unattenuated. This is thus the highest current obtainable at GIF++. With the help of the angular correction filters, the current depends only on the distance from the irradiator

³After traversing a length of x cm in a material, the intensity I of a beam of monoenergetic photons with original intensity I_0 amounts to $I=I_0e^{-\mu x}$. The following linear attenuation factors for photons with $E=662$ keV were used for the design of the filters: 0.116 mm^{-1} for Pb, 0.020 mm^{-1} for Al, 0.053 mm^{-1} for Fe.

along the z -coordinate and is uniform in all xy planes. The corresponding xz view of the current of 662 keV photons can be found in figure 11b.




Figure 3: Photon current in the vertical plane through the source (yz plane) at $x = 0.65$ m; attenuation filters at factor 1. With angular correction filters, the current of 662 keV photons is made uniform in xy planes.

2.5. Area monitoring

Ambient dose equivalent and ambient dose equivalent rates in the GIF++ zone are monitored by the Radiation Protection Group (RP) of CERN's Health and Safety unit using the RADIATION Monitoring System for the Environment and Safety⁴ (RAMSES) [11]. In the GIF++ facility, two RAMSES Induced Activity Monitors⁵ are installed at fixed locations. One is attached to the bunker wall upstream and the other downstream at a similar height. The monitors are connected to signal conditioning electronics contained within a rack mounted monitoring station. The monitoring stations are designed in such a way that they perform their function independently of their supervisory system. They are equipped with an uninterruptible power supply that allows them to assure their function without external electrical power for at least two hours. In the case of GIF++, RAMSES generates hardwired interlocks to the access control system to block access to the zone whilst the source is exposed. RAMSES allows remote on-line supervision of

⁴RAMSES comprises more than 400 radiation monitors (not including environmental monitors) and, in conjunction with two other systems, provides radiation monitoring throughout CERN's accelerators, experimental and service areas.

⁵PTW 32006 air filled 3 L ionisation chambers from ptw.de with a calibrated measurement range of $5 \mu\text{Sv/h} - 500 \text{mSv/h}$

all the measured variables as well as data logging and long-term archiving for off-line data analysis and reporting. The RAMSES installation is thus part of the safety infrastructure of the zone, but in addition provides radiation monitoring information for the users of the facility.

Within the framework of the EU-funded AIDA project, the Institute For Nuclear Research And Nuclear Energy in Sofia (Bulgaria), provided a Radiation Monitoring (RADMON) readout system for the monitoring of the integrated dose delivered by the photon source. The RADMON sensor was developed at CERN [12] as a flexible and convenient solution for radiation monitoring, and is currently being used by several experiments at CERN and external facilities. Various dosimeters with different sensitivities and dynamic ranges can be mounted on the RADMON Integrated Sensor Carrier(ISC) to monitor radiation fields with wide ranges of ionizing dose and particle fluence. Starting in October 2015, the RADMON readout system has been fully implemented within the GIF++ bunker. In total 12 RADMON sensors can be freely positioned in the downstream and upstream area of the facility. The sensors are read out automatically by the GIF++ Control System and data are made available via software through the DIP communication protocol. In contrast to the RAMSES monitors, the RADMONs are not a safety system but a dedicated radiation monitoring system for the GIF++ users.

3. Setup of simulations and measurements

3.1. Units

In the present paper, the air kerma⁶ K_a is used to quantify the absorbed dose in air. Kerma and absorbed dose have both the unit Gy and are closely related, but the kerma is usually more convenient to calculate [13]. The ambient dose equivalent⁷ $H^*(10)$, the unit used by area radiation monitors,

⁶The acronym kerma stands for kinetic energy relaxed in material. The kerma is defined as $K = \frac{dE_{tr}}{dm}$, where dE_{tr} is the sum of the initial kinetic energies of all the charged ionizing particles liberated by uncharged ionizing particles in a material of mass dm . The absorbed dose is defined as $D = \frac{d\bar{\epsilon}}{dm}$, with $d\bar{\epsilon}$ the mean energy imparted to matter of mass dm . Absorbed dose and kerma are numerically identical, provided that electron equilibrium is attained and radiative losses are negligible [14]. This is basically the case in the air of the radiation zone of GIF++.

⁷The ambient dose equivalent $H^*(10)$, an operational quantity for area monitoring, is measured in Sv and is used for strongly penetrating radiation like photons above 15 keV.

can be converted to air kerma K_a with the help of conversion factors [15].

The particle fluence is defined as $\Phi = \frac{dl}{dV}$, the total path length of the particle per unit volume [14]. The unit of the fluence is m^{-2} . The fluence rate or flux is defined as $\phi = \frac{d\Phi}{dt}$ and has the unit of $\text{m}^{-2}\text{s}^{-1}$. The deposited energy of a particle in matter is proportional to the particle flux, therefore flux is the adequate unit when dealing with detectors for calorimetry.

On the other hand, current is a measure of the net number of particles crossing a *flat surface* with a well-defined orientation. The unit of current is $\text{m}^{-2}\text{s}^{-1}$ and thus identical to the unit of flux. Current is meaningful in cases where particles are counted without any interest in their interactions. For example, a fully efficient infinitesimal thin detector would record each photon entering the detector independent of the actual energy deposited by the particle.

For the GIF++ it was decided, that the typical detector tested in the facility comes rather close to this model, and thus current and not flux was used as design quantity for the angular correction filter. In a directed radiation field flux and current are identical for normal incidence to the surface. At all other angles the flux is higher by a factor of $\cos^{-1}(\theta)$, with θ as the angle between incoming particle and surface normal of the scoring surface [16].

3.2. Simulation setup

Fluence and current in the GIF++ photon field were simulated with Geant4 10.0 and the G4EmLivermorePhysics physics list. For this purpose, the whole facility had been covered with a mesh of 5 cm x 5 cm x 5 cm scoring cubes. In each of the cubes, the photon fluence and photon current binned in 100 keV bins were calculated⁸. Additionally, for the measurement locations listed in table 1, the spectral distribution of the photons was simulated in 1 keV bins. From the simulated fluence, the air kerma K_a was calculated using the conversion factors published in reference [18]. For the albedo studies, the interactions of photons of different energies and angles of incidence with the materials present in the facility (lead, steel, concrete, aluminum) were simulated.

3.3. Measurement locations

Dose measurements were carried out in the GIF++ facility in March 2015, December 2015 and March 2016 in the positions shown in table 1.

⁸The primitive scorers *G4PSCellFlux* and *G4PSFlatSurfaceCurrent* were used [17].

D stands for positions downstream, U for positions upstream and I for a position outside the irradiation area. The origin of the GIF++ coordinate system (figure 1) is in x and y the position of the beam line, and in z the center of the source. In March 2015, the irradiator was at the closest position to the muon beam and has been slightly moved since October 2015.

Location, Time	Detector	Name	Coordinates		
			x [m]	y [m]	z [m]
Irradiator, March 2015	-	Source	0.65	0.0	0.0
Irradiator, since October 2015	-	Source	0.70	0.0	0.0
Near irradiator, March 2015	Automess 6150AD-15	I1	3.65	0.0	0.0
Downstream, March 2015	Automess 6150AD-15	D1	0.65	0.0	1.1
		D2	0.65	0.0	2.9
		D3	0.65	0.0	4.9
		D4	3.65	0.0	4.9
		D5	-2.35	0.0	4.9
	RAMSES	DR	-1.26	0.09	5.86
Upstream, March 2015	Automess 6150AD-15	U1	0.65	0.0	-1.1
		U2	0.65	0.0	-2.9
		U3	0.65	0.0	-4.9
		U3a	0.65	-0.7	-4.9
		U3b	0.65	-1.5	-4.9
		U4	-1.35	0.0	-2.9
		U5	-1.35	0.0	-4.2
	RAMSES	UR	3.8	0.05	-5.90
Downstream, December 2015	RADMON	Da	0.65	0.0	0.45
		Db	0.65	0.0	1.00
		Dc	2.70	1.0	5.48
Upstream, March 2016	RADMON	Ua	0.65	0.0	-0.45
		Ub	0.65	0.0	-1.27
		Uc	0.65	0.07	-2.95
		Ud	3.65	0.13	-5.79

Table 1: Irradiator and measurement positions upstream (U) and downstream (D)

3.4. RAMSES and Automess gamma probe 6150AD-15 measurements

The RAMSES data shown here have been taken in March 2015, prior to the installation of any user equipment. Additionally a gamma probe⁹ was used to measure the ambient dose $H^*(10)$. The probe's requirements for the linearity of the dose rate measurement allow a deviation of up to $\pm 10\%$ within the measuring range of 1 mSv/h - 9.99 Sv/h, in comparison to the dose

⁹The gamma probe 6150AD-15 [19], from Automess, contains a Geiger-Müller counting tube as detector and is used in combination with the dose rate meter 6150AD [20].

rate of a 333 kBq ^{137}Cs calibration source. The energy range extends from 65 keV to 3 MeV. The nominal angular range is $\pm 45^\circ$ around the preferential direction perpendicular to the axis of the tube. The combined energy and directional dependence shows a maximum deviation of up to $\pm 40\%$ for all energies and directions compared to 662 keV photons from ^{137}Cs arriving in the preferential direction [19, 20]. The ambient dose equivalent $H^*(10)$ was converted to air kerma K_a using the factors described in reference [21].

3.5. RADMON measurements

In December 2015 RADMON [12] measurements were conducted in the downstream area, and in March 2016 in the upstream area. All the RADMON have been equipped with an on-board temperature sensor and two RADFETs for ionizing dose measurement¹⁰. The choice was driven by the need for a device with sensitivity in the range of several mGy, but capable to integrate doses up to the tens of kGy range. As a passive integrating sensor, the RADMON gives as information the total cumulative dose. Normally it serves as device for monitoring radiation levels, but can also be used as a dose rate dosimeter. Due to the very small active area of the sensor, the length of the cables and the precision of the electronics readout, the minimum detectable dose rate at GIF++ was found to be in the order of 10 mGy/h. Consequently, a consistent dose rate measurement at GIF++ can be achieved only by operating the sensors at an adequately high dose rate, or by allowing a sufficient integration time to obtain a measurable dose increase. In order to fully test the RADMON performance in the GIF++ photon field and to check the correct functioning of the readout system, several calibration measurements have been performed. The presence of other experimental equipment in the zone lead to slightly modified RADMON positions compared to the survey in March 2015, and also affected the measurements.

The experimental data have been collected in two runs. The measurements in the downstream area were performed over two weeks of irradiation in December 2015. In that period the attenuation factors were varied between 1 and 100. The source duty cycle and the different attenuation factors were taken into account when calculating the dose rates. Measurements in the upstream area were conducted in March 2016 over three days of operation, with the source always on and the attenuation factor always equal to 1. The

¹⁰As RADFET a REM 250 from radfet.com and a LAAS 1600 from laas.fr were used.

measured dose rate was automatically corrected for temperature variations, although the variation during this test stayed within $\pm 5^\circ\text{C}$, which is lower than the minimum needed to increase the dose readout by one bit. Additionally, the losses related to annealing were negligible, due to the relatively short exposure time. Since April 2016, the GIF++ bunker has been equipped with an air conditioning system that allows the control of the temperature and thus limits the temperature variations. The annealing on the other hand has to be taken into account in long-term measurements or after periods of long inactivity of the sensor.

4. Results

4.1. Measurements and simulations of the filter attenuation factors

An attenuation of 1 means that the source is not attenuated, and is subsequently called *fully open*. The maximum attenuation factor of 46415 is called *fully closed*. Table 2 shows that for the lower attenuation factors, the dose attenuation measured with the Automess gamma probe 6150AD-15 is comparable to the nominal attenuation of the 662 keV photons. For factors greater than 10 though, the effective dose attenuation is considerably lower than the nominal attenuation factor, since scattered photons with an energy smaller than 662 keV contribute substantially.

Nominal Attenuation	Filter Combination	Measured data	
		Dose Rate [mGy/h]	Dose Attenuation
1	A1 B1 C1	470.00	-
1.5	A1 B2 C1	400.00	1.2
2.2	A1 B1 C2	211.00	2.2
4.6	A1 B1 C3	105.00	4.5
10	A2 B1 C1	55.00	8.8
100	A3 B1 C1	6.50	72.3
100	A1 B3 C1	6.20	75.8
464	A1 B3 C3	1.59	295.6
4642	A2 B3 C3	0.22	2156.0
46415	A3 B3 C3	0.05	9400.0

Table 2: Nominal attenuation factors (attenuation of the 662 keV photons) of some filter settings and measured effective attenuation.

Table 3 displays the nominal and simulated attenuation of the photon current in position U1. The values in the different energy ranges are expressed as ratio of unattenuated over attenuated current. As explained in

section 2.4, the nominal attenuation factor of the filters is the attenuation of the 662 keV photons. The attenuation for lower energy photons deviates from this factor. In general, photons with energies between 100 keV and 300 keV are attenuated to a larger extent than the attenuation factor implies, whereas photons with energies smaller than 100 keV and between 400 keV and 600 keV are attenuated less. Depending on the energy of the incoming photons, a different percentage of the photons Compton scatters or reacts via the photoelectric effect. This makes it hard to predict the exact attenuation per energy range. The attenuation filters for detector tests should therefore be chosen carefully, considering how the sensitivity of the detectors depends on the energy.

Nominal Attenuation	0-100 keV	100-200 keV	200-300 keV	300-400 keV	400-500 keV	500-600 keV	600-662 keV	0-662 keV	661-662 keV
1.0	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.5	0.74	4.11	2.47	1.41	1.15	1.18	1.41	1.42	1.45
2.2	1.19	7.3	5.7	2.10	1.56	1.55	2.02	2.0	2.12
3.2	1.63	10.4	8.6	2.89	1.94	1.97	2.87	2.8	3.10
4.6	2.3	13.5	13.2	4.28	2.80	2.68	4.09	3.9	4.50
6.8	3.3	18.8	18.5	5.9	3.65	3.50	5.78	5.4	6.54
10	5.0	19.6	19.0	8.8	4.69	4.50	8.22	7.3	9.47
14.7	6.3	32	30	11.8	6.2	5.85	11.8	10	13.8
21.5	8.7	47	58	17.7	9.3	8.2	16.7	15	19.9
31.6	12.6	62	84	24.1	12.0	11.1	24.1	20	29.5

Table 3: Nominal and simulated attenuation of photon current in position U1. The values in the different energy ranges are expressed as ratio of unattenuated over attenuated current. The intensity of the unattenuated photon current in U1 can be found in table 5.

Figure 4a shows the spectra of the photon current in location D1 for the attenuation factors 1, 10 and 100. In addition to the narrow 662 keV peak, a broad low energy component is visible. In fact the photons arrive already at the attenuation filters with this low energy component. Before even reaching the angular correction filter, the source capsule and the irradiator collimator already cause an amount of scattering that broadens the spectrum. Scattering in the angular correction filters and the bunker (walls, floor and roof) adds further low energy contributions to the spectrum. As expected, the intensity of the photons with an energy of 662 keV is reduced by a factor of 10 or 100, in agreement with the nominal attenuation of the lead filters.




Figure 4: Simulated spectra (bin size 5 keV) in location D1: a) Downstream attenuation factors of 1, 10 and 100 with upstream side closed; b) Crosstalk between downstream and upstream side with D open/U closed, D closed/U open and D closed/U closed. The narrow and very high main 662 keV peak can be seen in both figures at the far right.

Equivalent to the situation in position U1 described in table 3, the 400 keV to 600 keV photons are attenuated less, and the 100 keV to 300 keV photons are attenuated more than the nominal attenuation factor. Clearly visible in the spectra are the characteristic ^{82}Pb K-shell X-ray peaks around 80 keV, which cannot be resolved individually though, due to the energy binning.

Figure 4b shows three spectra in location D1, one with the downstream filters fully open and the upstream filters fully closed, one with the downstream filters fully closed and the upstream filters fully open and the third one with both sides fully closed. The two spectra with D closed show that when opening U, the rate in D increases significantly. By Compton scattering multiple times, photons from the upstream opening manage to arrive in the downstream zone of the facility. The absolute intensity of this *crosstalk* photon current is nevertheless small. Therefore the field in the measurement zone can be regarded as basically independent from the field in the opposing zone, unless a very large attenuation factor is used in the measurement zone.

4.2. Simulations of degraded photons and albedo

The photon current is modified by the interaction of photons with the materials present in the GIF++ facility. The materials concerned are lead (irradiator, filters), steel (filters, floor), aluminium (filters) and concrete (surrounding bunker enclosure). For the available photon energies of 662 keV or below, the main processes involved are Compton scattering and photoelectric effect. Following the photoelectric effect in lead, there is a high probability that the atom de-excites by emitting fluorescent X-rays. To better understand the photon current modification, these processes were simulated for photons of different energies and angles of incidence. Through collisions with electrons of dense materials, photons may lose a fraction of their energy along their travel. Therefore, in addition to the monochromatic 662 keV photons from ^{137}Cs , a low energy component of *degraded* photons develops within the irradiator. This low energy component is already present when the photons emerge from the small thin-walled capsule containing the active material¹¹. Interactions in the material subsequently traversed further modify the spectral shape of degraded photons, as illustrated in figure 5a for photons emerging from the capsule, from the angular correction filter, and from an exemplary attenuation filter of nominal factor 100. The peak around 80 keV corresponds to the K_α fluorescence line expected for lead. The vertical scale is normalized to one emerging 662 keV photon. For large attenuation factors, a general trend is visible. In comparison with the nominal attenuation factor for the 662 keV photons, the attenuation is more pronounced below 400 keV, but less pronounced above 400 keV. The fraction of degraded photons is coarsely the same at all stages, that means the number of degraded photons is also reduced when the number of 662 keV photons is reduced by absorption filters. The degraded photons amount to about 46% of the photons that reach the angular correction filter. Behind the angular correction filter, 39% of the photons that emerge from the irradiator within its 37° by 37° aperture are degraded. Behind the filter with a nominal attenuation of 100, the final fraction of degraded photons reaches 56%.

All photons emitted by the irradiator will interact with the surrounding material in the bunker and will finally be absorbed. The photons that are not absorbed when impinging on a wall, but manage to re-enter into the bunker,

¹¹The wall of the capsule is with 1.75 mm actually 1 mm thicker than assumed in the simulation.





Figure 5: Calculated energy distribution of (a) degraded photons emerging from the irradiator, per emerging 662 keV photon, and (b) of albedo photons from 662 keV photons impinging on a wall, for three wall materials, per 662 keV incident photon.

are called *albedo* photons. They are expected to be mainly back-scattered photons from Compton scattering; for lead some fluorescence photons contribute to the albedo. The calculated energy distribution of albedo photons is shown in figure 5b for 662 keV photons impinging with angles of 0° and 37° with respect to the surface normal on a wall of infinite thickness and made of concrete, steel or lead. The vertical scale is per photon incident on the wall.

While colliding with a nearly free electron, the lowest energy of the scattered photon corresponds to a scattering angle of 180°. For 662 keV photons this leads, independent of the wall material, to a back-scattered photon of about 184 keV. Photons back-scattered at other angles will have somewhat higher energy. Inside the wall, before emerging again, the photon may suffer further Compton scatterings, which will lower the energy of the albedo photon. Also incident photons of energies lower than 662 keV will extend the albedo spectrum to lower energies. As visible in figure 5b, the concrete and steel spectra are dominated by this Compton back-scatter peak, and it is also visible in the lead spectrum. The contribution from the photoelectric effect, approximately proportional to Z^3 (Z is the nuclear charge of the target material) and to about E^{-3} (E is the energy of the incident photon), is therefore only relevant for lead in terms of probability and of energy. The characteristic $K\alpha$ and $K\beta$ X-ray fluorescence lines [22] of 72 to 88 keV are prominent in the lead albedo spectra. For all three materials, the spectra at 0° and at 37° incidence are almost identical, except in the tail region above 250 keV. At 0°

(37°) incidence the fraction of albedo per incident 662 keV photon is 24.6% (29.5%) for concrete, 14.7% (18.6%) for steel and 1.9% (2.8%) for lead.

To give an overview of the amount of albedo under different conditions relevant at GIF++, figure 6a illustrates the dependence of albedo on the energy of the incident photon, for incident angles from 0° to 45°. The lower (higher) border of the bands is for 0° (45°). The influence of the angle of incidence on the back-scatter probability is small. Down to about 250 keV the probability of *reflecting* a photon is roughly the same as for 662 keV. In this main region of energies it is an order of magnitude lower for lead than for concrete. Below 250 keV the probability decreases, except for lead which shows a large increase related to the photoelectric effect.



(a) Back-scatter probability of photons

(b) Penetration depth of reflected photons

Figure 6: Back-scatter probability of incoming photons and penetration depth of reflected photons depending on material and incoming photon energy and angle.

It is interesting to see how deep a photon penetrates into a wall before emerging again. The calculated average depth reached by these photons, shown in figure 6b, decreases slowly from the largest depth at 662 keV down to about 200 keV; the standard deviation has almost the same value as the average. With a wall thickness of twice this average depth the albedo production is thus saturated. Therefore with a 2 mm thick lead layer on walls, ceiling and floor, the amount of albedo photons could be reduced by one order of magnitude with respect to concrete. The large penetration depth in concrete, together with the angular distribution of the scattered photons inside the wall material has as consequence that the photons will emerge at a

location, which may be different from the location of the impinging photon. The emission of albedo photons is isotropic in the azimuth angle with regard to the surface normal of the scattering surface. The polar emission angle is almost independent from the energy and the angle of incidence of the incoming photon from the source. At an incidence angle of 0° and 37° , the average polar emission angle amounts to 50° . At the wall surface the exit point of albedo from 662 keV photons is on average at about 3 cm distance from the impact point, with a 3.5 cm standard deviation. At 100 cm from the wall, the exit point is on average 160 cm away from the impact point, with 68% of the photons having an exit point that is less than 155 cm away. This shows that albedo is expected to be widespread in the bunker.

The angular distribution of albedo photons, as they are originating at points distributed over the whole GIF++ bunker, is of course very different from the distribution for photons from the irradiator. The final distributions of photon rate, angle, energy in the GIF++ bunker will follow the principles described in this section, while reflecting the complexity of the actual geometry of the bunker and of all the installed equipment like detectors in the facility. Simulations providing a guideline for GIF++ as a whole are described in the following sections.

4.3. Measurements and simulations of the dose rate

Figure 7 shows the simulated absorbed dose in air in the GIF++ bunker. The measurement locations are marked in black. In figure 7a the irradiator was fully open downstream and fully closed upstream, whereas in figure 7b the irradiator was fully closed downstream and fully open upstream. A fully closed irradiator outlet means an attenuation factor of 46415. The ratio of the doses in U1 and D1 reflects this attenuation in both figures. They demonstrate that the photons scatter significantly from the bunker walls, floor and roof. A quiet spot in the facility does not exist.¹² Nevertheless, the two figures confirm that the downstream and upstream zones of the GIF++ facility are basically independent. The intensity of the scattered photons depends on the exact position in the facility. A position closer to the walls like U6 suffers more from albedo than position D5, but both positions see about the same amount of direct photons. Furthermore the figures show that

¹²The dose contribution from photons passing through the irradiator shielding is negligible.

the angular correction filters do not only create a uniform current of 662 keV photons over the xy-planes within the irradiation regions, but also lead to a dose distribution that almost exclusively depends on z .




Figure 7: Absorbed dose in air [$\mu\text{Gy/h}$] in xz plane at $y=0.0\text{m}$ of the facility.

Measurements, as shown in Table 4, are compared with the simulations for the locations indicated in figures 7 and 8. For the simulations, in addition to the statistical error, a position uncertainty of ± 5 cm was used, as taken from the estimated position uncertainty of the measurement probes.

Given the Automess 6150AD-15 probe's allowed linearity deviation of $\pm 10\%$ and combined directional and energy deviation of $\pm 40\%$, a total dose measurement uncertainty of $\pm 40\%$ was assumed. The simulated dose rates are always larger than the measured dose rates with the Automess 6150AD-15 probe. In locations close to the irradiator, like the locations D1 and U1, where the majority of the dose is caused by 662 keV photons, measurement and simulation agree to about 15%. Even at location I1, outside of the irradiation area, measurement and simulation agree within 40%. Within the irradiation area, in locations with the same absolute value of the z -coordinate but different x coordinate, the measured dose rates vary less than 20%. For the positions U3, U3a and U3b at different y coordinates, the variation is within 10%. Dose rate for positions downstream and upstream, on the axis of the source and with the same distance from the source, agree within 10%. This proves that the downstream and upstream zones of the facility have very similar radiation fields.

Position	Detector	Downstream open, Upstream open		
		Measured dose rate	Simulated dose rate	Ratio*
		[mGy/h]	[mGy/h]	[%]
I1	Automess 6150AD-15	1.3(7)	2.2(2)	57
D1	Automess 6150AD-15	-	410(42)	-
D2	Automess 6150AD-15	-	56(3)	-
D3	Automess 6150AD-15	17(7)	22(1)	77
D4	Automess 6150AD-15	15(6)	22(1)	69
D5	Automess 6150AD-15	13(5)	21(1)	60
DR	RAMSES	12(5)	15(1)	76
U1	Automess 6150AD-15	379(152)	412(43)	92
U2	Automess 6150AD-15	45(18)	55(3)	81
U3	Automess 6150AD-15	17(7)	22(1)	79
U3a	Automess 6150AD-15	20(8)	23(1)	88
U3b	Automess 6150AD-15	18(7)	23(1)	76
U4	Automess 6150AD-15	43(17)	63(4)	68
U5	Automess 6150AD-15	25(10)	32(1)	77
U6	Automess 6150AD-15	16(6)	24(1)	67
UR	RAMSES	11(4)	17(1)	66
Da	RADMON	2330(559)	2213(521)	105
Db	RADMON	470(60)	440(47)	107
Dc	RADMON	16(1)	18(1)	89
Ua	RADMON	2251(557)	2274(536)	99
Ub	RADMON	249(30)	283(25)	88
Uc	RADMON	40(4)	55(2)	73
Ud	RADMON	20(2)	18(1)	111

* Measured dose rate divided by simulated dose rate.

Table 4: Measured and simulated dose rate at the measurement locations in March 2015 (I1 to UR), December 2015 (Da to Dc) and March 2016 (Ua to Ud). Values in parentheses are the estimated uncertainties.

The RAMSES measurement took place in positions at the upstream and downstream end wall of the bunker. The value in UR agrees well with the Automess measurement in U6, whereas the RAMSES measurement in DR lies between the Automess measurement and the simulated value.

For the RADMON measurement locations in figure 8a, in addition to the ± 5 cm position uncertainty, a precision uncertainty of ± 7.5 % has been estimated. Figure 8b shows a very good agreement ($\leq 5\%$ difference) between measurement and simulation for positions close to the source. The difference between measurement and simulations increases with the distance from the source, but stays below 12% for all positions with the exception of Uc. The deviation in Uc might be explained with the presence of other experimental equipment in the zone during the measurements. The GIF++ source, due to the angular correction filters, is expected to provide a dose rate dependence mainly on z instead of on r like a point source. Consequently, the comparison in figure 8b is plotted as function of z. It shows that the power law is indeed a

good approximation for the intensity distribution along the z-axis, especially close to the source.

To summarize, all measured values show within +11% and -43% good agreement with the simulations.




Figure 8: RADMON measurements of absorbed dose [mGy/h].

4.4. Measurements and simulations of the photon current

As described in section 2.4, the GIF++ irradiator and filter system is designed to produce a homogeneous radiation field of $\pm 37^\circ$, with a sharp decrease at the edges. In August 2015, a Drift Tube (DT) chamber [23] from the experiment CMS, was placed at 4.9 m distance from the source and at the edge of the 37° irradiation cone. The four solid lines of figure 9 show the occupancy measured in four layers of 2.5 m long vertical drift cells of the 2 m wide drift chamber. The profiles measured by the four independent layers of 50 drift cells each look identical. Scaling the measured rates permits to compare the shape of the profile with simulation curves and it shows a good agreement for photon energies of at least 200 keV, suggesting that very low energy photons do not contribute to the measured signal.

To study the energy composition of the radiation field in GIF++, spectra of the photon current were simulated for the 14 measurement locations of March 2015. The spectra in figure 10 confirm the results presented in sections 4.2 and 4.3. Spectra in positions with the same z coordinate are basically identical. As expected, the spectrum in I1 does not contain any




Figure 9: Comparison of simulated photon current with the occupancy measured in drift cells of a CMS Drift Tube Chamber.

662 keV photons, but consists of photons that scattered multiple times. In all other spectra the narrow and very high main 662 keV ^{137}Cs peak is clearly visible at the far right. The concrete and steel back-scatter peak (section 4.2) is present in all spectra. In the spectra of positions U1 and D1, that are close to the irradiator and the filter systems, the characteristic ^{82}Pb K-shell X-rays are present.

Figures 11 and 12 depict the photon current at the height of the source in the xz plane of the facility. Thanks to the angular correction filters, the current of photons between 600 keV and 662 keV is uniform at given z value within the $\pm 37^\circ$ opening as displayed in figure 11b. This does not apply to the current of photons with energies below 500 keV. At a given z coordinate, the further away in x direction from the source a location is, the smaller the current. Due to the contribution from lower energy photons, the total current in figure 11a also shows some dependence from the x coordinate. In location I1, photons with an energy between 100 keV and 200 keV form the strongest contribution to the photon current as shown in figure 12c, whereas photons with an energy above 400 keV do not occur in this location. In the locations U4, U5 and U6, the current is somewhat enhanced (Figures 12b to 12d) due to scattering of photons from the nearby walls, since the upstream




Figure 10: Simulated spectra (bin size 5 keV) in different locations with irradiator fully open downstream and upstream. The narrow and very high main 662 keV peak can be seen in all figures at the far right.

zone of the GIF++ facility is narrower and has an 80 cm lower roof than the downstream zone. The absolute contribution of these scattered photons to the total current is nevertheless relatively small. Table 5 lists the contribution of the different energy ranges to the total photon current. Inside the $\pm 37^\circ$ wide irradiation area unattenuated 662 keV photons contribute between 33% and 54% of the total current. Directly in front of the irradiator about half of the photons are unattenuated photons.




Figure 11: Simulated unattenuated current of photons above 400 keV in xz plane at $y=0$ m. The largest total current amounts to 5×10^7 photons per cm^2 per second.




Figure 12: Simulated unattenuated current of photons between 0 keV to 400 keV in xz plane at $y=0$ m. Below 400 keV, the highest current is in the range from 100 keV to 200 keV.

	0-100 keV	100-200 keV	200-300 keV	300-400 keV	400-500 keV	500-600 keV	600-662 keV	0-662 keV	661-662 keV	
Position	[$10^6 \text{cm}^{-2} \text{s}^{-1}$]									%
D1	0.36	2.92	2.44	3.29	5.18	5.88	23.8	43.9	20.0	45.5
D2	0.17	0.72	0.45	0.35	0.67	0.83	3.34	6.52	2.79	42.8
D3	0.14	0.47	0.22	0.20	0.23	0.29	1.14	2.70	0.95	35.2
D4	0.12	0.38	0.19	0.13	0.14	0.15	1.28	2.39	1.17	48.7
D5	0.11	0.32	0.17	0.13	0.15	0.15	1.29	2.32	1.17	50.3
I1	0.13	0.35	0.08	0.008	0.005	0.0002	0.00	0.57	0.00	0.00
U1	0.39	2.96	2.44	3.30	5.14	5.89	23.8	43.9	20.0	45.5
U2	0.21	0.81	0.41	0.34	0.66	0.83	3.38	6.64	2.82	42.6
U3	0.19	0.57	0.28	0.20	0.23	0.28	1.15	2.91	0.96	33.1
U3 _a	0.18	0.54	0.27	0.21	0.27	0.29	1.15	2.90	0.96	33.3
U3 _b	0.14	0.47	0.26	0.19	0.26	0.31	1.18	2.82	1.01	36.0
U4	0.29	0.95	0.49	0.27	0.33	0.35	3.82	6.51	3.54	54.4
U5	0.34	0.86	0.45	0.32	0.29	0.26	1.71	4.23	1.52	35.9
U6	0.22	0.56	0.29	0.19	0.15	0.15	1.28	2.84	1.16	40.9

Table 5: Overview of simulated photon current [$10^6 \text{cm}^{-2} \text{s}^{-1}$]: downstream and upstream fully open. These are the highest currents available.

5. Conclusions

The new GIF++ radiation facility, operational since spring 2015, features an intense source of 662 keV photons. The irradiator has two openings of $\pm 37^\circ$ oriented towards a downstream and an upstream irradiation area. A high-energy muon beam passes close to the irradiator and permits to study detector performance while being irradiated at adjustable high rates. Each irradiation zone is equipped with a versatile filter system permitting to attenuate the current of 662 keV photons in 24 steps by up to a factor 4.6×10^4 . To improve uniformity over large planar detectors, integrated angular correction filters serve to ensure that the current of the unattenuated photons depends predominantly on the z coordinate. Lower energy photons, from interactions in irradiator and in surrounding material, contribute in a complex way to the radiation field. The photon current in the whole bunker has been simulated with Geant4. Photon currents of up to 5×10^7 photons per cm^2 per second are available at a distance of 1 m from the source. Between 33% and 54% of the photon current comes from unattenuated photons with an energy of 662 keV, the remainder are photons that lost energy mostly through Compton scattering in the lead of the filters, in the steel of the facility floor or in the concrete of walls and roof. RADMON measurements of the absorbed dose in air have been compared with simulations. The measurements agree to 12% with the simulations, and are well within expected uncertainties. The

same agreement is also found for the Automess 6150AD-15 measurements in locations close to the source. The maximum absorbed dose in air amounts to 2.2 Gy/h directly in front of the irradiator.

6. Acknowledgments

DP would like to acknowledge the support of the EU Horizon 2020 framework, BrightnESS project 676548.

References

- [1] S. Agosteo et al, *A facility for the test of large area muon chambers at high rates*, Nuclear Instruments and Methods in Physics Research A 452 (2000) 94-104.
- [2] European Organization for Nuclear Research (CERN), <http://home.cern/>.
- [3] Lyndon Evans and Philip Bryant, *The LHC Machine*, JINST 3 (2008) S08001.
- [4] High Luminosity Linear Hadron Collider (HL-LHC), <http://home.cern/topics/high-luminosity-lhc>.
- [5] M.R. Jaekel et al, *CERN GIF++: A new irradiation facility to test large-area particle detectors for the high-luminosity LHC program*, International Conference on Technology and Instrumentation in Particle Physics 2014, Amsterdam, Netherlands, 2 - 6 Jun 2014, PoS TIPP2014 (2014) 102, <http://pos.sissa.it/cgi-bin/reader/conf.cgi?confid=213>.
- [6] G. Aielli et al, *Detector and detector control system operational: GIF++ Infrastructure Commissioning and Utilization*, AIDA deliverable report AIDA-D8.6, 28 pages, 2015, <http://cds.cern.ch/record/1984406?ln=en>.
- [7] S. Agostinelli et al., *GEANT4: A Simulation toolkit*, Nuclear Instruments and Methods in Physics Research A 506 (2003) 250-303.

- [8] B. Biskup, E. Efthymiopoulos, A. Fabich, D. Pfeiffer, *Shielding Optimization for the New Gamma Irradiation Facility at CERN*, Manuscript to be submitted for publication.
- [9] VF, *VF a.s., Svitavská 588, 679 21 Cerná Hora, Czech Republic*, <http://www.vf.eu>.
- [10] Physikalisches Institut IIIA, RWTH Aachen University, O. Blumenthal-Str. 16, D-52074 Aachen, Germany.
- [11] G. Segura Millan, D. Perrin, L. Scibile, *RAMSES: The LHC Radiation Monitoring System for the Environment and Safety*, 10th ICALEPCS Int. Conf. on Accelerator & Large Expt. Physics Control Systems. Geneva, 10 - 14 Oct 2005, TH3B.1-3O (2005).
- [12] F. Ravotti, *Development and characterisation of radiation monitoring sensors for the high energy physics experiments of the CERN LHC accelerator*, CERN-THESIS-2007-013, <http://cds.cern.ch/record/1014776/files/thesis-2007-013.pdf>.
- [13] IAEA, *Dosimetry in Diagnostic Radiology: An International Code of Practice*, http://www-pub.iaea.org/MTCD/publications/PDF/TRS457_web.pdf.
- [14] ICRP, *Conversion Coefficients for Radiological Protection Quantities for External Radiation Exposures*, ICRP Publication 119, Ann. ICRP 40 (2-5), 2010.
- [15] ICRP, *Conversion Coefficients for use in Radiological Protection against External Radiation*, ICRP Publication 74, Ann. ICRP 26 (3-4), 1996.
- [16] M. Huhtinen, *The Radiation environment at the CMS experiment at the LHC*, <http://inspirehep.net/record/421028/files/mika.pdf> PhD thesis HU-SEFT-R-1996-14,1996.
- [17] Geant4 Primitive Scorers, <http://geant4.web.cern.ch/geant4/G4UsersDocuments/UsersGuides/ForApplicationDeveloper/html/Detector/hit.html>, Geant4 User Guide, 2016.
- [18] K.G. Veinot, N.E. Hertel, *Personal Dose Equivalent Conversion Coefficients for Photons to 1 GeV*, Radiation Protection Dosimetry Vol. 145 No. 1 (2011) 28-35.

- [19] Automation und Messtechnik GmbH, *Datasheet for Gamma Probes 6150AD-15 and 6150AD-18*, http://www.automess.de/Download/Prospekt_AD1518_E.pdf.
- [20] Automation und Messtechnik GmbH, *Operating Manual for the Dose Rate Meter 6150AD from 26.10.2005*, https://www.compass.cern.ch/compass/organisation/safety/documents/dosimeter_automess_6150AD.pdf.
- [21] Automation und Messtechnik GmbH, *Radiation quantities and units*, http://www.automess.de/Messgroessen_E.htm.
- [22] Tables of Physical & Chemical Constants (16th edition 1995), *4.2.1 X-ray absorption edges, characteristic X-ray lines and fluorescence yields*, http://www.kayelaby.npl.co.uk/atomic_and_nuclear_physics/4_2/4_2_1.html.
- [23] CMS Muon DT group, communication to GIF++ users, <https://indico.cern.ch/event/523267/>.